

Annual Drinking Water Quality Report for 2024
Village of Cassadaga
22 Mill Street, PO Box 286
Cassadaga, NY 14718
Public Water Supply ID# NY0600356

INTRODUCTION

To comply with State regulations, the Village of Cassadaga annually issues a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard; however, we did not meet all monitoring and reporting requirements. This is detailed in the “Is Our Water System Meeting Other Rules That Govern Operations?” section of the report.

This report provides an overview of last year’s water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards. If you have any questions about this report or concerns about your drinking water, please contact Sam Alaimo, Water Operator, at 716-595-3844 or the Village Offices at 716-595-3007. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled Village Board Meetings. The meetings are held in the Community Room on the 2nd and 4th Wednesday of every month at 7:00 PM.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department’s and the FDA’s regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves approximately 635 people through 371 service connections, along with the Lily Dale Assembly and the Cassadaga Job Corps Center. Our water source consists of three groundwater wells – well #1, well #4 and well #5. Well #5, the newest well, is treated by aeration to remove methane. Blended orthophosphate (Carus 8100) is added to the water from well #4 and #5 to reduce discoloration (brown water) caused by naturally occurring iron and manganese. Finally, chlorine is added to our water before it is pumped into the distribution system.

The NYS DOH has completed a source water assessment for Wells #1 and #4 based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is or will become contaminated. While some inorganic contaminants were detected in our water, it should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants from natural sources. The presence of contaminants does not necessarily indicate that the water poses a health risk. See section “Are there contaminants in our drinking water?” for a list of the contaminants that have been detected.

The source water assessment has rated our wells 1 and 4 as having a medium susceptibility to microbials, nitrates, industrial solvents, and other industrial contaminants. There has not been an assessment done on well

#5. These ratings are due primarily to the close proximity of permitted discharge facilities (septic systems that discharge wastewater into the environment and are regulated by the state and/or federal government) to the wells and the associated activity in the assessment area. The wells draw from a confined aquifer. A copy of the assessment can be obtained by contacting us as noted above.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Chautauqua County Department of Health and Human Services at 716-753-4481.

TABLE OF DETECTED CONTAMINANTS

Contaminant	Violation	Date of Sample	Level Detected	Unit Measurement	Regulatory Limit MCL/AL	MCLG	Likely Source of Contamination
INORGANIC CONTAMINANTS							
Barium (Well #1)	No	8/19/24	0.068	mg/l	2(MCL)	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Barium (Well #4)	No	8/19/24	0.193	mg/l	2(MCL)	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Barium (Well #5)	No	11/4/24	0.460	mg/l	2(MCL)	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Manganese (Well #4)	No	8/28/24	28	ug/l	300(MCL)	N/A	Naturally occurring. Can be indicative of landfill contamination
Iron (Well #5)	No	8/28/24	220	ug/l	300(MCL)	N/A	Naturally occurring.
Manganese (Well #5)	No	8/28/24	14	ug/l	300(MCL)	N/A	Naturally occurring. Can be indicative of landfill contamination
Copper(1)	No	8/26/23 – 8/29/23	0.295 Range: 0.015- 0.342	mg/l	1.3(AL)	1.3	Corrosion of household plumbing systems, Erosion of natural deposits;
Lead(2)	No	8/26/23 – 8/29/23	0.5 Range: ND-1.2	ug/l	15(AL)	0	Corrosion of household plumbing systems; Erosion of natural deposits.
VOLATILE ORGANIC CONTAMINANTS							
1,1,1-Trichloroethane (Well #1)	No	8/19/24	0.60	ug/l	5.0(MCL)	N/A	Discharge from metal degreasing sites and other factories
Dibromomethane (Well #5)	No	11/4/24	0.8	ug/l	5.0(MCL)	N/A	Dibromomethane finds limited use in chemical synthesis, as a solvent and as a gage fluid. It may be released to the environment during this use, as well as in its production and transport. Also used as a solvent for fats, waxes and resins and an ingredient of fire extinguisher fluids.
Dichloromethane (Well #5)	No	11/4/24	0.7	ug/l	5.0(MCL)	0	Discharge from pharmaceutical and chemical factories.
STAGE 2 DISINFECTION BYPRODUCTS (Bard Rd)							
Total Trihalomethanes	No	8/28/24	17.11	ug/l	80(MCL)	N/A	By-products of drinking water chlorination. TTHM's are formed when source water contains large amounts of organic matter.
STAGE 2 DISINFECTION BYPRODUCTS (Ames Common)							
Haloacetic Acids	No	8/28/24	3.7	ug/l	60(MCL)	N/A	By-products of drinking water chlorination.
RADIOLOGICALS							
Radium 228 (Well #4)	No	3/16/22	0.274	Pci/L	5(MCL)	N/A	Erosion of natural deposits.

Gross Alpha (Well #4)	No	3/16/22	0.876	Pci/L	15(MCL)	0	Erosion of natural deposits.
Gross Beta(3) (Well #4)	No	3/16/22	0.347	Pci/L	8(MCL)	0	Decay of natural deposits and man-made emissions.
Uranium (Well #4)	No	3/16/22	0.286	ug/l	30	0	Erosion of natural deposits
Radium 228 (Well #5)	No	5/23/23	0.380	Pci/L	5(MCL)	N/A	Erosion of natural deposits.
Gross Alpha (Well #5)	No	5/23/23	1.10	Pci/L	15(MCL)	0	Erosion of natural deposits.
Gross Beta(3) (Well #5)	No	5/23/23	1.95	Pci/L	8(MCL)	0	Decay of natural deposits and man-made emissions.

DISINFECTANTS

Chlorine Residual Entry Point #1	No	Daily (2024)	Avg.= 0.61 Range: 0.33 – 1.05	mg/l	4(MCL)	N/A	Water additive used to control microbes
Chlorine Residual Entry Point #4	No	Daily (2024)	Avg.= 1.34 Range: 0.42 – 2.20	mg/l	4(MCL)	N/A	Water additive used to control microbes
Chlorine Residual Entry Point #5(4)	No	Daily (2023)	Avg.= 1.16 Range: 0.37 – 3.10	mg/l	4(MCL)	N/A	Water additive used to control microbes

Notes:

1- The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the Copper values detected at your water system. In this case 10 samples were collected at your water systems and the 90th percentile value was calculated to be the second highest result value and that result was 0.295 mg/l. The action level for Copper was not exceeded at any of the sites tested.

2- The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the Lead values detected at your water system. In this case 10 samples were collected at your water system and the 90th percentile value was calculated to be the second highest result value and that result was 0.5 ug/l. The action level for lead was not exceeded at any of the sites tested.

3- The NYSDOH considers 50 pCi/l to be the level of concern for beta particles.

4- Due to mechanical issues, Well #5 did not provide service to the Village in 2024. The numbers represented are from 2023, the last year it was in service.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant that is allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations in 2024. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. Lead and copper were detected within the system but of the 10 samples collected none were found exceeding the action levels. We are however required to present the following information on Lead in drinking water:

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The Village of Cassadaga is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact The Village of Cassadaga contact Sam Alaimo, Water Operator, at 716-595-3844 or the Village Offices at 716-595-3007. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During 2024, our system was in compliance with applicable State drinking water operating requirements, but not monitoring and reporting requirements. We were issued a monitoring violation by the Chautauqua County Health Department for failing to monitor for microbiological contaminants during the month of May, and therefore cannot be sure of the quality of your drinking water for these contaminants during that time.

This past year we monitored for chlorine residual on a daily basis but failed to provide the chlorine monitoring report for the month of May to the Chautauqua County Health Department within the allotted submission period. This does not pose a threat to the quality of our water supply.

INFORMATION ON LEAD SERVICE LINE INVENTORY

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible by visiting our website @ cassadaganewyork.org and selecting on the Home Page: **Lead Service Line Inventory NY0600356.xlsx**. or by visiting the state's website at: <https://health.data.ny.gov/Health/New-York-State-Lead-Service-Line-Inventory-Map/fkii-zkcq>. You can search by location on the map, but please note, the Village of Cassadaga information is not populated yet.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their

health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

INFORMATION FOR NON-ENGLISH SPEAKING RESIDENTS

Spanish

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ♦ Saving water saves energy and some of the costs associated with both necessities of life.
- ♦ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ♦ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ♦ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So, get a run for your money and load it to capacity.
- ♦ Turn off the tap when brushing your teeth.
- ♦ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ♦ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. Sam Alaimo has his Class C Water Operator license and oversees our water system.

The rate structure will continue with a \$95.00 debt service per dwelling unit and a water rate usage of \$6.75 per thousand gallons beginning June 1, 2025. The December 1, 2025, billing will reflect an increase of \$.50 per 1000 gallons usage. Partial payments will be accepted by the Village Clerk with a total to be paid within 60 days; henceforth after that date past due notices will be issued. Water billings go out on June 1st and December 1st. Shut off notices will be sent in March or April for water bills that are 2 cycles past due.

Normal business hours are Tuesdays and Thursdays from 8:30AM to 4:00PM.